

4e kw 2019

Waternet

Locatie:

Leiduin

Naam:

Rein water

Omschrijving	Eenheid	gemiddelde	Norm
Aluminium	µg/l	1	< 200
Calcium	mg/l	41	
Chloride	mg/l	71	< 150
EGV (elek. geleid.verm. 20°C)	mS/m	54.6	
Waterstofcarbonaat	mg/l	190	> 60
Totale hardheid	mmol/l	1.40	>1
Totale hardheid	°Duits	7.85	
Magnesium	mg/l	9	
Natrium	mg/l	69	< 150
Ammonium	mg/l NH4	<0.02	< 0.20
Nitraat	mg/l NO3	3.28	< 50
pH berekend	pH	8.1	7.0<pH<9.5
Verzadigingsindex S.l. berekend	pH	0.33	> -0.2
Sulfaat	mg/l	42	< 150
Temperatuur	°C	11.1	< 25
Coli 37°C	kve/100 ml	0	0
Legionella	kve/l	<100	< 100